



Box R Water Analysis Laboratory

567 NW Second Street
Prineville, Oregon 97754
541-447-4911

Mr. Wade Peasley

Aug 19, 2016

c/o Harney County School District #3

550 North Court Ave.

Burns, OR 97720

Sample Nbr: X023292


Dear Mr. Peasley,

Attached is a copy of your drinking water – Lead – test results, sampled on Aug 5, 2016, at Burns High School, Burns, OR. Your analysis was performed by Neilson Research Corp. in Medford, OR. Please do not hesitate to call Box R Water Analysis Laboratory with any questions you may have in regards to your water testing.

Thank you for using Box R Water Analysis Laboratory, we appreciate your business.

Sincerely,

Sherri K. Miyazaki – Box R Water Analysis Laboratory Director



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

8/19/2016

Sherri Miyazaki
Box R Waterlab
567 NW Second Street
Prineville, OR 97754

TEL: (541) 447-4911
FAX (541) 447-4917

RE: X023292 Burns High School

Order No.: 1608517

Dear Sherri Miyazaki:

Neilson Research Corporation received 12 sample(s) on 8/9/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Box R Waterlab
Project: X023292 Burns High School
Lab Order: 1608517

Date: 19-Aug-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608517
NRC Sample ID: 1608517-01A
Collection Date: 8/5/2016 6:12:00 AM
Received Date: 8/9/2016 10:06:00 AM
Reported Date: 8/19/2016 2:06:28 PM

Sample Information:

X023292 Burns High School

Client Sample ID: X023292 #1
Collectors Name: Wade Peasley
Sample Location: Kitchen
Source:

ANALYTICAL RESULTS

Analyses	NELAP			Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited	Result						
Lead	EPA 200.8	A	0.0407	*CF	0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608517**
NRC Sample ID: **1608517-02A**
Collection Date: **8/5/2016 6:12:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/19/2016 2:06:28 PM**

Sample Information:

X023292 Burns High School

Client Sample ID: X023292 #2
Collectors Name: Wade Peasley
Sample Location: DF in Wt Rm
Source:

ANALYTICAL RESULTS

Analyses	NELAP		Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited							
Lead	EPA 200.8	A	0.000181		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608517
NRC Sample ID: 1608517-03A
Collection Date: 8/5/2016 6:12:00 AM
Received Date: 8/9/2016 10:06:00 AM
Reported Date: 8/19/2016 2:06:28 PM

Sample Information:

X023292 Burns High School

Client Sample ID: X023292 #3
Collectors Name: Wade Peasley
Sample Location: DF Boy's Locker Rm
Source:

ANALYTICAL RESULTS

Analyses	NELAP			Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited	Result						
Lead	EPA 200.8	A	0.00207		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608517
NRC Sample ID: 1608517-04A
Collection Date: 8/5/2016 6:12:00 AM
Received Date: 8/9/2016 10:06:00 AM
Reported Date: 8/19/2016 2:06:28 PM

Sample Information:

X023292 Burns High School

Client Sample ID: X023292 #4
Collectors Name: Wade Peasley
Sample Location: DF Girl's Locker Rm
Source:

ANALYTICAL RESULTS

Analyses	NELAP			Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited	Result						
Lead	EPA 200.8	A	0.00163		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608517
NRC Sample ID: 1608517-05A
Collection Date: 8/5/2016 6:12:00 AM
Received Date: 8/9/2016 10:06:00 AM
Reported Date: 8/19/2016 2:06:28 PM

Sample Information:

X023292 Burns High School

Client Sample ID: X023292 #5
Collectors Name: Wade Peasley
Sample Location: DF Between Locker Rms
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	ND		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608517
NRC Sample ID: 1608517-06A
Collection Date: 8/5/2016 6:12:00 AM
Received Date: 8/9/2016 10:06:00 AM
Reported Date: 8/19/2016 2:06:28 PM

Sample Information:

X023292 Burns High School

Client Sample ID: X023292 #6
Collectors Name: Wade Peasley
Sample Location: Room 41
Source:

ANALYTICAL RESULTS

Analyses	NELAP			Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited	Result						
Lead	EPA 200.8	A	0.00376		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608517**
NRC Sample ID: **1608517-07A**
Collection Date: **8/5/2016 6:12:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/19/2016 2:06:28 PM**

Sample Information:

X023292 Burns High School

Client Sample ID: X023292 #7
Collectors Name: Wade Peasley
Sample Location: Booster Rm DF
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	ND		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608517**
NRC Sample ID: **1608517-08A**
Collection Date: **8/5/2016 6:12:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/19/2016 2:06:28 PM**

Sample Information:

X023292 Burns High School

Client Sample ID: X023292 #8
Collectors Name: Wade Peasley
Sample Location: DF Front Hall
Source:

ANALYTICAL RESULTS

Analyses	NELAP			Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited	Result						
Lead	EPA 200.8	A	0.00259		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608517**
NRC Sample ID: **1608517-09A**
Collection Date: **8/5/2016 6:12:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/19/2016 2:06:28 PM**

Sample Information:

X023292 Burns High School

Client Sample ID: X023292 #9
Collectors Name: Wade Peasley
Sample Location: DF Center Hall
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPÄ 200.8	A	0.00347		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608517**
NRC Sample ID: **1608517-10A**
Collection Date: **8/5/2016 6:12:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/19/2016 2:06:28 PM**

Sample Information:

X023292 Burns High School

Client Sample ID: X023292 #10
Collectors Name: Wade Peasley
Sample Location: DF South Hall
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00326		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608517
NRC Sample ID: 1608517-11A
Collection Date: 8/5/2016 6:34:00 AM
Received Date: 8/9/2016 10:06:00 AM
Reported Date: 8/19/2016 2:06:28 PM

Sample Information:

X023292 Burns High School

Client Sample ID: X023292 #11
Collectors Name: Wade Peasley
Sample Location: DF West Hall
Source:

ANALYTICAL RESULTS

Analyses	NELAP			Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited	Result						
Lead	EPA 200.8	A	0.00105		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608517**
NRC Sample ID: **1608517-12A**
Collection Date: **8/5/2016 6:35:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/19/2016 2:06:28 PM**

Sample Information:

X023292 Burns High School

Client Sample ID: X023292 #12
Collectors Name: Wade Peasley
Sample Location: Staff Room
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00282		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

DATA FLAGS

- B Analyte detected in the associated method blank.
- BA BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
- C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
- C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
- CF Results confirmed by re-analysis.
- CU Cleanup performed as specified by method.
- D1 The diesel elution pattern for the sample is not typical.
- D2 The sample appears to be a heavier hydrocarbon range than diesel.
- D3 The sample appears to be a lighter hydrocarbon range than diesel.
- D4 Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
- D5 Detected hydrocarbons in the diesel range appear to be weathered diesel.
- E Estimated value.
- ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
- FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
- G1 The gasoline elution pattern for the sample is not typical.
- G2 The sample appears to be a heavier hydrocarbon range than gasoline.
- G3 The sample appears to be a lighter hydrocarbon range than gasoline.
- G4 Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
- HP Sample re-analysis performed outside of method specified holding time.
- HR Sample received outside of method specified holding time.
- HS Sample analyzed for volatile organics contained headspace.
- HT At the client's request, the sample was analyzed outside of method specified holding time.
- H Analysis performed outside of method specified holding time.
- J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
- MI Surrogate or Matrix Spike recovery is out of control limits due to matrix interference. Sample results may be biased.
- N See Case Narrative on page 2 of report.
- Q Closing continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
- R Relative percent difference (RPD) is outside of the accepted recovery limits.
- R1 Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
- R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
- R4 Duplicate analysis failed due to result being at or near method reporting limit.
- S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
- S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
- SC Sub-contracted to another laboratory for analysis.
- SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
- T Toxicity Characteristic Leaching Procedure – Sample submitted contained < 0.5% solids. If the waste contains <0.5% dry solids, the liquid portion of the waste, after filtration, is defined as the TCLP extract.
- # Value exceeds regulatory level for TCLP contaminant.
- X1 The motor oil elution pattern for the sample is not typical.
- X2 The sample appears to be a heavier hydrocarbon range than motor oil.
- X3 The sample appears to be a lighter hydrocarbon range than motor oil.
- * Value exceeds Maximum Contaminant Level or is outside the acceptable range.

NRC SOP QA-1104/AD-3100

Revision 3

Effective Date: 6/3/16

CLIENT: Box R Waterlab
 Work Order: 1608517
 Project: X023292 Burns High School

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	SampType	TestCode	Units	Prep Date	RunNo	Client ID	Batch ID	TestNo	(EPA 200.8)	Analysis Date	SeqNo	Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual	
MB-36194	MBLK	ICPMS_200.8	mg/L	8/10/2016	89203	ZZZZZ	36194	EPA 200.8	(EPA 200.8)	8/14/2016	1344993	Lead	ND	0.000103										
LCS-36194	LCS	ICPMS_200.8	mg/L	8/10/2016	89203	ZZZZZ	36194	EPA 200.8	(EPA 200.8)	8/14/2016	1344994	Lead	0.09541	0.000104	0.1	0	95.4	85	115					
1608517-12AMS	MS	ICPMS_200.8	mg/L	8/10/2016	89203	X023292 #12	36194	EPA 200.8	(EPA 200.8)	8/14/2016	1345013	Lead	0.09718	0.000104	0.1	0.002817	94.4	70	130					
1608517-12AMSD	MSD	ICPMS_200.8	mg/L	8/10/2016	89203	X023292 #12	36194	EPA 200.8	(EPA 200.8)	8/14/2016	1345014	Lead	0.09728	0.000104	0.1	0.002817	94.5	70	130	0.09718	0.107	20		

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Environmental Testing Laboratory
 245 South Grape Street * Medford, OR 97501
 (541) 770-5678 Fax (541) 770-2901

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: Box R Water Analysis Laboratory	Project Name: HARNEY COUNTY SCHOOL DISTRICT #3	Company Name: Edward Peasley	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: 567 NW Second St. Prineville, Or 97754	Project Number: X023292 (1-12)	Address: 550 N. Court Ave Buena OR 97609	<input type="checkbox"/> 5 Business Days (50% surcharge)
Phone: _____	Report To: SK MIYAZAKI	P.O.# N/A	<input type="checkbox"/> 3 Business Days (75% surcharge)
Collected By (Print): Wade Peasley	Copy To: Wade Peasley		<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Collected By (Sign): <i>[Signature]</i>			Other _____
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			

Section E
Sample Information

(Buena High School)

Sample ID	Comp/Grab	Matrix	Date Collected	Time Collected	No. of Containers	Analysis Requested	Remarks/Field Data
X023292 (19784)	Grab	DW	08/06/16	0600	1	X	Kitchen
(19773)					1	X	DE in WTRm
(19836)					1	X	DE Boys Locker
(19817)					1	X	DE Girls Locker
(19844)					1	X	DE Belknap Locker
(19781)					1	X	Room 41
(19806)					1	X	Booster Room DE
(19828)					1	X	DE Front Hall
(19797)					1	X	DE Center Hall
(19794)					1	X	DE South Hall

*Matrix DW - Drinking Water WW - Wastewater W - Water S - Sol/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive

Relinquished By: <i>[Signature]</i>	Sign	Print	Date	Time
Received By: <i>[Signature]</i>		SK Miyazaki	08/06/16	1330
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <i>[Signature]</i>		O. Manning	8/9/16	10:00

Section G
Lab Use Only

Am

File Blank Included Yes No

Received Via UPS FedEx Other Hand

12 BOTTLES



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: Box R Water	Project Name: Harney County School District #3	Company Name: Wade Peasley	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: Analysis Laboratory	Project Number: X023292 (1-12)	Address: 550 N. Court Ave	<input type="checkbox"/> 5 Business Days (50% surcharge)
Email: 567 NW Second St.	Report To: SK Miyazaki	Burns OR 97703	<input type="checkbox"/> 3 Business Days (75% surcharge)
Phone: Prineville, Or 97754	Copy To: Wade Peasley	P.O. # N/A	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Collected By (Print): Wade Peasley			Other _____
Collected By (Sign): Wade Peasley			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			

Sample Information						No. of Containers	Analysis Requested										Remarks/Field Data		
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected															
X023292 (cont 19810)	Grab	DW	080516	0634	1	Lead													

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: [Signature]		Shawn Miyazaki	080516	1330
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:				

Section G Lab Use Only
Field Blank Included: <input type="checkbox"/> Yes <input type="checkbox"/> No

Received Via UPS FedEx Other Hand