



Box R Water Analysis Laboratory

567 NW Second Street
Prineville, Oregon 97754
541-447-4911

Mr. Wade Peasley

Aug 16, 2016

c/o Harney County School District #3

550 North Court Ave.

Burns, OR 97720

Sample Nbr: X023291


Dear Mr. Peasley,

Attached is a copy of your drinking water – Lead – test results, sampled on Aug 5, 2016, at Hines Middle School, Hines, OR. Your analysis was performed by Neilson Research Corp. in Medford, OR. Please do not hesitate to call Box R Water Analysis Laboratory with any questions you may have in regards to your water testing.

Thank you for using Box R Water Analysis Laboratory, we appreciate your business.

Sincerely,

Sherri K. Miyazaki – Box R Water Analysis Laboratory Director



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

8/16/2016

Sherri Miyazaki
Box R Waterlab
567 NW Second Street
Prineville, OR 97754
TEL: (541) 447-4911
FAX (541) 447-4917

RE: X023291 Hines Middle School

Order No.: 1608524

Dear Sherri Miyazaki:

Neilson Research Corporation received 9 sample(s) on 8/9/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Box R Waterlab
Project: X023291 Hines Middle School
Lab Order: 1608524

Date: 16-Aug-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608524**
NRC Sample ID: **1608524-01A**
Collection Date: **8/5/2016 5:35:00 AM**
Received Date: **8/9/2016 10:09:00 AM**
Reported Date: **8/16/2016 7:39:09 AM**

Sample Information:

X023291 Hines Middle School

Client Sample ID: X023291-01
Collectors Name: Wade Peasley
Sample Location: Girl's Locker Room
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00703		0.000103	mg/L	0.020 AL	8/10/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608524
NRC Sample ID: 1608524-02A
Collection Date: 8/5/2016 5:37:00 AM
Received Date: 8/9/2016 10:09:00 AM
Reported Date: 8/16/2016 7:39:09 AM

Sample Information:

X023291 Hines Middle School

Client Sample ID: X023291-02
Collectors Name: Wade Peasley
Sample Location: Boy's Locker Room
Source: City Water

ANALYTICAL RESULTS

Analyses	NELAP			MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited	Result					
Lead	EPA 200.8	A	0.00750	0.000103	mg/L	0.020 AL	8/10/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608524**
NRC Sample ID: **1608524-03A**
Collection Date: **8/5/2016 5:38:00 AM**
Received Date: **8/9/2016 10:09:00 AM**
Reported Date: **8/16/2016 7:39:09 AM**

Sample Information:

X023291 Hines Middle School

Client Sample ID: X023291-03
Collectors Name: Wade Peasley
Sample Location: Gym
Source: City Water

ANALYTICAL RESULTS

Analyses	NELAP		Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited							
Lead	EPA 200.8	A	0.000672		0.000103	mg/L	0.020 AL	8/10/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608524
NRC Sample ID: 1608524-04A
Collection Date: 8/5/2016 5:42:00 AM
Received Date: 8/9/2016 10:09:00 AM
Reported Date: 8/16/2016 7:39:09 AM

Sample Information:

X023291 Hines Middle School

Client Sample ID: X023291-04
Collectors Name: Wade Peasley
Sample Location: DF by Office
Source: City Water

ANALYTICAL RESULTS

Analyses	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited Result						
Lead	EPA 200.8	A 0.00433		0.000103	mg/L	0.020 AL	8/10/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608524
NRC Sample ID: 1608524-05A
Collection Date: 8/5/2016 5:44:00 AM
Received Date: 8/9/2016 10:09:00 AM
Reported Date: 8/16/2016 7:39:09 AM

Sample Information:

X023291 Hines Middle School

Client Sample ID: X023291-05
Collectors Name: Wade Peasley
Sample Location: DF by Boy's/Girl's RR
Source: City Water

ANALYTICAL RESULTS

Analyses	NELAP		Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited							
Lead	EPA 200.8	A	0.0121		0.000103	mg/L	0.020 AL	8/10/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608524
NRC Sample ID: 1608524-06A
Collection Date: 8/5/2016 5:46:00 AM
Received Date: 8/9/2016 10:09:00 AM
Reported Date: 8/16/2016 7:39:09 AM

Sample Information:

X023291 Hines Middle School

Client Sample ID: X023291-06
Collectors Name: Wade Peasley
Sample Location: DF by Art Room
Source: City Water

ANALYTICAL RESULTS

Analyses	NELAP		Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited							
Lead	EPA 200.8	A	0.00388		0.000103	mg/L	0.020 AL	8/10/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608524**
NRC Sample ID: **1608524-07A**
Collection Date: **8/5/2016 5:48:00 AM**
Received Date: **8/9/2016 10:09:00 AM**
Reported Date: **8/16/2016 7:39:09 AM**

Sample Information:

X023291 Hines Middle School

Client Sample ID: X023291-07
Collectors Name: Wade Peasley
Sample Location: DF by Cafeteria
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00683		0.000103	mg/L	0.020 AL	8/10/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608524**
NRC Sample ID: **1608524-08A**
Collection Date: **8/5/2016 5:49:00 AM**
Received Date: **8/9/2016 10:09:00 AM**
Reported Date: **8/16/2016 7:39:09 AM**

Sample Information:

X023291 Hines Middle School

Client Sample ID: X023291-08
Collectors Name: Wade Peasley
Sample Location: DF in Cafeteria
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00951		0.000103	mg/L	0.020 AL	8/10/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608524
NRC Sample ID: 1608524-09A
Collection Date: 8/5/2016 5:50:00 AM
Received Date: 8/9/2016 10:09:00 AM
Reported Date: 8/16/2016 7:39:09 AM

Sample Information:

X023291 Hines Middle School

Client Sample ID: X023291-09
Collectors Name: Wade Peasley
Sample Location: Kitchen
Source: City Water

ANALYTICAL RESULTS

Analyses	NELAP			Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited	Result						
Lead	EPA 200.8	A	0.00149		0.000103	mg/L	0.020 AL	8/10/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

CLIENT: Box R Waterlab
 Work Order: 1608524
 Project: X023291 Hines Middle School

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	MB-36184	SampType:	MBLK	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	8/10/2016	RunNo:	89136			
Client ID:	ZZZZZ	Batch ID:	36184	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	8/10/2016	SeqNo:	1342686			
Analyte		Result		MRL		SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		ND		0.000103										

Sample ID	LCS-36184	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	8/10/2016	RunNo:	89136			
Client ID:	ZZZZZ	Batch ID:	36184	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	8/10/2016	SeqNo:	1342687			
Analyte		Result		MRL		SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09878		0.000104		0.1	0	98.8	85	115				

Sample ID	1608520-49AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	8/10/2016	RunNo:	89136			
Client ID:	ZZZZZ	Batch ID:	36184	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	8/10/2016	SeqNo:	1342698			
Analyte		Result		MRL		SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09560		0.000104		0.1	0.00004406	95.6	70	130				

Sample ID	1608520-49AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	8/10/2016	RunNo:	89136			
Client ID:	ZZZZZ	Batch ID:	36184	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	8/10/2016	SeqNo:	1342699			
Analyte		Result		MRL		SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09684		0.000104		0.1	0.00004406	96.8	70	130	0.0956	1.30	20	

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: Box R Water Analysis Laboratory		Project Name: Harnett County School District #3		Attention: Charles Peasley		<input checked="" type="checkbox"/> Standard 10-14 Days	
Address: 567 NW Second St. Prineville, Or 97754		Project Number: X023291 (1-9)		Company Name: Charles Peasley		<input type="checkbox"/> 5 Business Days (50% surcharge)	
Email: 567 NW Second St. Prineville, Or 97754		Report To: S.K. Mujazaki		Address: 550 N. Court Ave. Burns OR 97720		<input type="checkbox"/> 3 Business Days (75% surcharge)	
Phone: 541 777 9111		Copy To: Wade Peasley		P.O. # N/A		<input type="checkbox"/> 24 - 48 hours (100% surcharge)	
Collected By (Print): Wade Peasley						Other _____	
Collected By (Sign): <i>Wade Peasley</i>						Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No	
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No							
Fax Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No							

**Section E
Sample Information** (Hines Middle School)

1608524

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	Remarks/Field Data
X023291 (1976)	Grab	DW	080516	0535	1		Girls locker room
(19753)				0537	1		Boys Locker Room
(19788)				0538	1		Gym
(19737)				0542	1		DE by Office
(19815)				0544	1		DF by Biology Rm
(19842)				0546	1		DF by Art Rm
(19813)				0548	1		DF by Cafeteria
(19819)				0549	1		DF in Cafeteria Kitchen
(19808)				0550	1		

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

01
02
03
04
05
06
07
08
09

**Section F
Relinquish/Receive**

Relinquished By: <i>[Signature]</i>	Sign	Print: S.K. Mujazaki	Date: 080516	Time: 1330
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <i>[Signature]</i>		S. Manay	8/19/16	10:09

**Section G
Lab Use Only** *Ans*

GC Seal Intact	Yes	No	NA
Field Blank Included	Yes	No	
Received Via	UPS	FedEX	Other <input type="checkbox"/> Hand